

Appendix D
Excel Template for Lead Results

Client : PARS Environmental
Project ID : Clinton Public School, 10 School St., Clinton, NJ

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
FIELD BLANK	N	P21-11343-01	PAS	NJDEP 15001	10/12/2021	5:30	SM 3113 B	10/15/2021	10:44	-0.32	2.00	1	N	ND
CPS-1-H NURSE-WC-P	N	P21-11343-02	PAS	NJDEP 15001	10/12/2021	5:31	SM 3113 B	10/15/2021	10:47	5.44	2.00	1	N	
CPS-1-NURSE-NS-P	N	P21-11343-03	PAS	NJDEP 15001	10/12/2021	5:32	SM 3113 B	10/15/2021	11:09	5.71	2.00	1	N	
CPS-1-NURSE-BF-P	N	P21-11343-04	PAS	NJDEP 15001	10/12/2021	5:33	SM 3113 B	10/15/2021	11:13	6.30	2.00	1	N	
CPS-1-MO-TL-P	N	P21-11343-05	PAS	NJDEP 15001	10/12/2021	5:34	SM 3113 B	10/15/2021	11:16	1.07	2.00	1	N	J
CPS-1-MO-SB-P	N	P21-11343-06	PAS	NJDEP 15001	10/12/2021	5:36	SM 3113 B	10/15/2021	11:20	1.27	2.00	1	N	J
CPS-1-RM 16-CF-P	N	P21-11343-07	PAS	NJDEP 15001	10/12/2021	5:37	SM 3113 B	10/15/2021	11:23	4.65	2.00	1	N	
CPS-1-RM 27-SB-P	N	P21-11343-08	PAS	NJDEP 15001	10/12/2021	5:38	SM 3113 B	10/15/2021	17:13	21.3	6.00	3	N	
CPS-1-RM 26-SB-P	N	P21-11343-09	PAS	NJDEP 15001	10/12/2021	5:40	SM 3113 B	10/15/2021	17:17	279	40.0	20	N	
CPS-1-STAFF RM-TL-P	N	P21-11343-10	PAS	NJDEP 15001	10/12/2021	5:42	SM 3113 B	10/15/2021	13:17	2.73	2.00	1	N	
CPS-1-RM 25-SB-P	N	P21-11343-11	PAS	NJDEP 15001	10/12/2021	5:44	SM 3113 B	10/15/2021	11:40	1.47	2.00	1	N	J
CPS-1-RM 24-SB-P	N	P21-11343-12	PAS	NJDEP 15001	10/12/2021	5:46	SM 3113 B	10/15/2021	11:58	1.40	2.00	1	N	J
CPS-1-RM 23-SB-P	N	P21-11343-13	PAS	NJDEP 15001	10/12/2021	5:48	SM 3113 B	10/15/2021	12:02	7.10	2.00	1	N	
CPS-1-RM 18-SB-P	N	P21-11343-14	PAS	NJDEP 15001	10/12/2021	5:50	SM 3113 B	10/15/2021	12:06	0.0083	2.00	1	N	ND
CPS-1-H RM 19-WC-P	N	P21-11343-15	PAS	NJDEP 15001	10/12/2021	5:52	SM 3113 B	10/15/2021	12:09	0.0083	2.00	1	N	ND
CPS-1-H RM 19-BT-P	N	P21-11343-16	PAS	NJDEP 15001	10/12/2021	5:54	SM 3113 B	10/15/2021	12:13	0.0083	2.00	1	N	ND
CPS-1-RM 19-SB-P	N	P21-11343-17	PAS	NJDEP 15001	10/12/2021	5:56	SM 3113 B	10/15/2021	17:20	47.1	10.0	5	N	
CPS-1-RM 20-SB-P	N	P21-11343-18	PAS	NJDEP 15001	10/12/2021	5:58	SM 3113 B	10/15/2021	12:20	12.9	2.00	1	N	
CPS-1-RM 21-SB-P	N	P21-11343-19	PAS	NJDEP 15001	10/12/2021	6:00	SM 3113 B	10/15/2021	12:24	8.69	2.00	1	N	
CPS-1-RM 8-SB-P	N	P21-11343-20	PAS	NJDEP 15001	10/12/2021	6:02	SM 3113 B	10/15/2021	17:24	29.5	10.0	5	N	
CPS-1-H BLR-BT-P	N	P21-11343-21	PAS	NJDEP 15001	10/12/2021	6:04	SM 3113 B	10/15/2021	12:31	0.270	2.00	1	N	ND
CPS-1-H BLR-WC-P	N	P21-11343-22	PAS	NJDEP 15001	10/12/2021	6:06	SM 3113 B	10/15/2021	12:42	-0.12	2.00	1	N	ND
CPS-1-RM 9-SB-P	N	P21-11343-23	PAS	NJDEP 15001	10/12/2021	6:08	SM 3113 B	10/15/2021	12:46	1.86	2.00	1	N	J
CPS-1-H RM 11-WC-P	N	P21-11343-24	PAS	NJDEP 15001	10/12/2021	6:10	SM 3113 B	10/18/2021	12:52	17.2	4.00	2	N	
CPS-1-RM 10-SB-P	N	P21-11343-25	PAS	NJDEP 15001	10/12/2021	6:12	SM 3113 B	10/15/2021	13:28	3.72	2.00	1	Y	
CPS-1-H ALL PURPOSE RM-BT-P	N	P21-11343-26	PAS	NJDEP 15001	10/12/2021	6:14	SM 3113 B	10/15/2021	13:42	1.80	2.00	1	N	J
CPS-1-H ALL PURPOSE RM-WC-P	N	P21-11343-27	PAS	NJDEP 15001	10/12/2021	6:16	SM 3113 B	10/15/2021	13:46	1.40	2.00	1	N	J
CPS-1-KITCHEN-FP1-P	N	P21-11343-28	PAS	NJDEP 15001	10/12/2021	6:18	SM 3113 B	10/15/2021	13:49	4.38	2.00	1	N	
CPS-1-KITCHEN-FP2-P	N	P21-11343-29	PAS	NJDEP 15001	10/12/2021	6:20	SM 3113 B	10/15/2021	13:53	8.82	2.00	1	N	
CPS-1-KITCHEN-SP-P	N	P21-11343-30	PAS	NJDEP 15001	10/12/2021	6:21	SM 3113 B	10/15/2021	17:28	26.7	6.00	3	N	
CPS-1-RM 5-SB-P	N	P21-11343-31	PAS	NJDEP 15001	10/12/2021	6:22	SM 3113 B	10/15/2021	14:00	2.46	2.00	1	N	
CPS-1-RM 4-SB-P	N	P21-11343-32	PAS	NJDEP 15001	10/12/2021	6:23	SM 3113 B	10/15/2021	14:34	1.20	2.00	1	N	J
CPS-1-RM 1-SB-P	N	P21-11343-33	PAS	NJDEP 15001	10/12/2021	6:24	SM 3113 B	10/15/2021	14:45	0.470	2.00	1	Y	ND
CPS-1-RM 2-SB-P	N	P21-11343-34	PAS	NJDEP 15001	10/12/2021	6:25	SM 3113 B	10/15/2021	14:48	2.46	2.00	1	N	
CPS-1-H RM 3-WC1-P	N	P21-11343-35	PAS	NJDEP 15001	10/12/2021	6:26	SM 3113 B	10/15/2021	14:52	2.99	2.00	1	N	
CPS-1-H RM 3-WC2-P	N	P21-11343-36	PAS	NJDEP 15001	10/12/2021	6:27	SM 3113 B	10/15/2021	14:55	2.79	2.00	1	N	
CPS-1-RM 3-CF-P	N	P21-11343-37	PAS	NJDEP 15001	10/12/2021	6:28	SM 3113 B	10/15/2021	14:59	1.73	2.00	1	N	J
CPS-2-H RM 32-BT-P	N	P21-11343-38	PAS	NJDEP 15001	10/12/2021	6:30	SM 3113 B	10/15/2021	15:02	-0.26	2.00	1	N	ND
CPS-2-H RM 32-WC-P	N	P21-11343-39	PAS	NJDEP 15001	10/12/2021	6:32	SM 3113 B	10/15/2021	15:06	-0.19	2.00	1	N	ND
CPS-2-RM 34-SB-P	N	P21-11343-40	PAS	NJDEP 15001	10/12/2021	6:34	SM 3113 B	10/15/2021	15:10	2.53	2.00	1	N	
CPS-2-RM 36-SB-P	N	P21-11343-41	PAS	NJDEP 15001	10/12/2021	6:36	SM 3113 B	10/15/2021	16:44	31.9	20.0	10	N	
CPS-2-H RM 35-WC1-P	N	P21-11343-42	PAS	NJDEP 15001	10/12/2021	6:38	SM 3113 B	10/15/2021	17:06	0.540	2.00	1	N	ND
CPS-2-H RM 35-WC2-P	N	P21-11343-43	PAS	NJDEP 15001	10/12/2021	6:40	SM 3113 B	10/15/2021	17:09	0.540	2.00	1	N	ND

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib
- ST= Steamer